

Tagig Water Testing Laboratory

37 General Luna St., Tuktukan, Taguig City
Telephone No.: 02 263-1611 D.O.H. Accreditation 13-0016-1819-LW-2

Source of Sample PURIFIED

Laboratory No. 19-1694

Date and Time Collected 02/22/19 9:38 AM

Sampled By EINIGO

Name of Establishment BLUE VELVET DRINKING WATER

Address B12 L39 Ph1 EP Village, Pinagsama
Taguig City

PHYSICAL CHARACTERISTIC

Color COLORLESS Odor ODORLESS Turbidity CLEAR

BACTERIOLOGICAL EXAMINATION OF WATER

| PARAMETERS | METHODOLOGY | NO. OF (+) TUBE (OUT OF _____ TUBES) | RESULT MPN/ ¹⁰⁰ _____ml. | * PNSDW STANDARD | REMARKS |
|------------------------------|------------------------------|---|--|----------------------------|---------|
| Total Coliform | MULTIPLE TUBE FERMENTAION | 0 | LESS THAN 1.1 mpn/100ml | LESS THAN 1.1 mpn/100ml | PASSED |
| Fecal Coliform | MULTIPLE TUBE FERMENTAION | 0 | LESS THAN 1.1 mpn/100ml | LESS THAN 1.1 mpn/100ml | PASSED |
| Heterotrophic Plate Count | Pour Plate | | 5 | <500 CFU/ml > | PASSED |


* Philippine National Standard for Drinking Water (P.N.S.D.W.)

Note: This results were obtained and based at the time of test and only to the particular sample submitted

References: **Philippine National Standard for Drinking Water**
Standard Methods for Examination of Water and Waste Water, 20th Edition 1995


IFTIZAR N. HARON, MD
LIC.No. 0119158

PATHOLOGIST



DELIA A. CRUZ, RMT LIC.# 1606
MEDICAL TECHNOLOGIST